

Compliance Statement

No. 2025-628

Unscreened Permanent Link, Class E (with ground continuity)

Company

Corning Optical Communications GmbH & Co. KG
Profilstr. 4
58093 Hagen
Germany

Permanent Link Identification (2 connector model)

Horizontal cable:

F/UTP 450/23 Cat.6, LSZH™/FRNC, 4P, Dca / CCXEDE-DD047-V000\$-## (\$=color, ##=length)

RJ45 connector for telecommunications outlet and patch panel:

E250 FTP OCK6Fx, E250Fx Jack, RJ45 Vol, Cat.6, (Unscreened connector with ground continuity)

Generic cabling standards - Class E Permanent Link requirements

- ISO/IEC 11801-1:2017 (Ed. 1.0) / ISO/IEC 11801-2:2017 (Ed. 1.0)
- EN 50173-1:2018 / EN 50173-2:2018
- TIA-568.2-E:2024

Technical report

12531124-02, DANAK-19/25311

EC Cabling product ID

5595

CS valid until


1 February 2027

This product has been tested by FORCE Technology and complies with the electrical requirements of the above specified standards and "Terms and conditions for the EC VERIFIED programme for Generic and Coaxial Cabling", DQP231006. The product takes part in a maintenance of certification schedule, which implies that FORCE Technology performs a sample test of the product once a year.

Hørsholm, 19 November 2025



Nis Jepsen
Specialist, Project Manager



Lars Lindskov Pedersen
Senior Team Leader, Test Manager

